

HOW EDIS USES THE DATA CAPTURED FOR REPORTING ELECTRICAL COMPLIANCE

After reading this document you should understand how EDIS uses data captured during electrical inspection and testing to report on electrical compliance. The document explains how the test coverage is calculated and a best practice for entering data into key fields to ensure the resulting compliance reports provide a view that allows data driven decision-making during the planning, reporting and execution of electrical compliance programmes.

Contents

PURPOSE OF THIS DOCUMENT	2
ELECTRICAL COMPLIANCE REQUIREMENT.....	2
THE EDIS CYCLE	2
IDENTIFYING THE DISTRIBUTION BOARDS AND CIRCUITS THAT REQUIRE INSPECTION AND TESTING ..	3
TESTING THE DISTRIBUTION BOARDS.....	5
Entering test results and observations.....	5
COMPLETING THE CERTIFICATE AND UPDATING THE COMPLIANCE DETAILS.....	6
The RESULTING DATA UPDATES.....	7
Last/next test dates for the circuits	7
Observations and recommendations.....	8
AFTER TESTING AND CERTIFICATE COMPLETION.....	9
Circuit results	9
Distribution board Schedule updated.....	10
THE UPDATED COMPLIANCE REPORTS.....	11
CONCLUSION AND RECOMMENDATIONS	12



PURPOSE OF THIS DOCUMENT

The primary purpose of the document is to illustrate how the data entered into the EDIS system enables better electrical compliance decision making and reporting, if the correct format is used.

The document demonstrates the end-to-end EDIS cycle, and how the recording of **test results influences the last test/ next test date**, and how the **last test/next test date affects the compliance reporting**.


For context purposes the introduction to the document provides a very brief explanation of the electrical compliance requirements and the EDIS cycle. The Document also provides a 'worked example' using a single distribution board.

ELECTRICAL COMPLIANCE REQUIREMENT

An electrical compliance process requires a risk assessment, this is typically done in the form of an EICR (Electrical Inspection Condition Report), the results are captured into a format described in BS7671 Condition Report model forms. The report provides a commentary and assessment of the condition of the electrical installation.

THE EDIS CYCLE

The EDIS cycle is a system and process to facilitate the reporting and status of electrical compliance.



The EDIS Cycle automates the data handling for this process by tracking the inspections, actions required following from Observations.

The cycle starts with a compliance requirement that identified what needs to be Inspected and Tested. These items are inspected and the condition of these is then recorded in a certificate. After testing and remediation, the compliance can then be reported.

Managing, tracking and reporting on the compliance requirement:

EDIS identified and managed the compliance requirement in two ways:

1. Tracking the last test date of a circuit (and the recommended next test date), the circuits last test date is used to determine the distribution board test dates.
2. Tracking the observations and associated actions, this is done via the Action Require list which is created when Observation and recommendations are included in an EICR

If the next test date is in the future and there are no incomplete actions, it implies that the system has been inspected and any recommendations have been remediated or re-assigned.

As time passes the system needs to be re-tested, and the compliance reports are updated.

IDENTIFYING THE DISTRIBUTION BOARDS AND CIRCUITS THAT REQUIRE INSPECTION AND TESTING

To identify which distribution boards, need to be tested compliance report with different levels of detail can be generated.

The report below is for a single building and it reports that there are 21 circuits due for testing in the Belsize building.

INTERIM STATUS REPORT AS AT 30 DECEMBER 2023															
Estate:		Demo Estate													
Building Name	Test Coverage	C1	C2	C3	FI	LIM	NV	FIO	NCFI	ERR	Energised Ccts (Total non-spare)	Ccts Not Due for testin	Ccts Due for testing	Last 5 Inspection Dates	Latest Inspected Certificate
Belsize	0%	0	0	0	0	0	0	0	0	0	21	0	21	30/01/2019	11500

A more detailed compliance report displaying board/circuit details can be generated to identify specific boards and circuits that need testing. As an example, the distribution board schedule below shows the status of the Last test and Next test dates prior to testing. In this example **the last test date is 01/01/2019, with a next test date set for 01/01/2024**

CR-01/1 DB

Circuit Number and Phase	Circuit Designation	Type of wiring	Reference Method	Number of Points served	Circuit Conductors: csa		Max. disconnection time permitted by BS 7671 (s)	Overcurrent Protection Device				RCD operating current, I _{Δn} (mA)	Maximum Z _s permitted by BS 7671	Test Date - Next Test
					Live (mm ²)	cpc (mm ²)		BS (EN)	Type No	Rating (A)	Short-circuit capacity (kA)			
1 - L1	Socket on Panel 1 & Lowerator	B	B	2	4	4	0.4	60898	C	20	N/A	1	10	01/01/2019-01/01/2024
1 - L2	Socket on Panel 3	B	B	1	4	4	0.4	60898	C	20	N/A	1	10	01/01/2019-01/01/2024
1 - L3	Socket on Panel 4	B	B	1	4	4	0.4	60898	C	20	N/A	1	10	01/01/2019-01/01/2024
2 - L1	Induction Hob 1 Socket	B	B	1	2.5	2.5	0.4	60898	C	16	N/A	1.3	10	01/01/2019-01/01/2024
2 - L2	Induction Hob 2 Socket	B	B	1	2.5	2.5	0.4	60898	C	16	N/A	1.3	10	01/01/2019-01/01/2024
2 - L3	Cold Well	B	B	1	2.5	2.5	0.4	60898	C	16	N/A	1.3	10	01/01/2019-01/01/2024
3 - L1	Soup & Lowerator	B	B	2	2.5/4	2.5/4	0.4	60898	C	16	N/A	1.3	10	01/01/2019-01/01/2024
3 - L2	Hot Cupboard Near	B	B	1	2.5	2.5	0.4	60898	C	16	N/A	1.3	10	01/01/2019-01/01/2024
3 - L3	Hot Cupboard Far	B	B	1	2.5	2.5	0.4	60898	C	16	N/A	1.3	10	01/01/2019-01/01/2024
4 - L1	Hot Plate 6	B	B	1	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	01/01/2019-01/01/2024
4 - L2	Heat Lamps 6	B	B	1	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	01/01/2019-01/01/2024
4 - L3	Hot Plate 5	B	B	1	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	01/01/2019-01/01/2024
5 - L1	Heat Lamps 5	B	B	3	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	01/01/2019-01/01/2024
5 - L2	Hot Plate 4	B	B	1	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	01/01/2019-01/01/2024
5 - L3	Heat Lamps 4	B	B	3	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	01/01/2019-01/01/2024
6 - L1	Hot Plate 3	B	B	1	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	01/01/2019-01/01/2024
6 - L2	Heat Lamps 3	B	B	3	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	01/01/2019-01/01/2024
6 - L3	Hot Plate 2	B	B	1	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	01/01/2019-01/01/2024
7 - L1	Heat Lamps 2	B	B	3	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	01/01/2019-01/01/2024
7 - L2	Trayside Lights	B	B	1	1.5	1.5	0.4	60898	C	6	N/A	3.6	10	01/01/2019-01/01/2024
7 - L3	Plinth Lights	B	B	1	1.5	1.5	0.4	60898	C	6	N/A	3.6	10	01/01/2019-01/01/2024

TESTING THE DISTRIBUTION BOARDS

During the testing of the distribution board, there are test readings and observations, in this example the observations are associated with a circuit. The schedule below shows the Circuit schedule of tests and provides an example of how the test results and observation can be recorded.

The example has been developed to illustrate how different situation can be handled when capturing the information. The information entered will determine how the circuit test dates and observations are handled by the EDIS system

Circuit Number	Phase	Sub-Main	TPN (Phases supply source point)	Circuit Designation	Polarity (Y/N)	Max Zs ELI Rec	RCD		AFDD		Observation Group (Available for organisations)	Observation (Select or type text)	Classification Code: 1,2,3,4,5,FIO C1,C2,C3 N/V,LIM,NCF
							Trip Time (ms) x 1	Test Button Operation (Y/N)	Manual AFDD Test Button Operation (Y/N)				
SORT													
1	L1	N	N	Socket on Panel 1 & Lower							TEST LIMITATIONS	lim1- ACCESS RESTRICTED	F1
1	L2	N	N	Socket on Panel 3							TEST LIMITATIONS	lim2 - NOT ABLE TO OPEN BOARD	LIM
1	L3	N	N	Socket on Panel 4							TEST LIMITATIONS	Lim3 - could not locate	F1
2	L1	N	N	Induction Hob 1 Socket							-	-	-
2	L2	N	N	Induction Hob 2 Socket							-	-	-
2	L3	N	N	Cold Well							-	-	-
3	L1	N	N	Soup & Lowerator							-	-	-
3	L2	N	N	Hot Cupboard Near							-	-	-
3	L3	N	N	Hot Cupboard Far							-	-	-
4	L1	N	N	Hot Plate 6	Y	0.11	N/A	N/A	N/A		TEST LIMITATIONS	Zs by calculation	FIO
4	L2	N	N	Heat Lamps 6	Y	0.11	N/A	N/A	N/A		TEST LIMITATIONS	Zs by calculation	FIO
4	L3	N	N	Hot Plate 5	Y	0.16	N/A	N/A	N/A		TEST LIMITATIONS	Zs by calculation	FIO
5	L1	N	N	Heat Lamps 5	Y	lim	N/A	N/A	N/A		TEST LIMITATIONS	Zs not possible due to...	LIM
5	L2	N	N	Heat Plate 4	Y	lim	N/A	N/A	N/A		TEST LIMITATIONS	Zs not possible due to...	LIM
5	L3	N	N	Heat Lamps 4	Y	lim	N/A	N/A	N/A		TEST LIMITATIONS	Zs not possible due to...	LIM
6	L1	N	N	Hot Plate 3	Y	0.11	N/A	N/A	N/A			No RCD/RCBO Protection.	C3
6	L2	N	N	Heat Lamps 3	Y	0.11	N/A	N/A	N/A			Broken Socket outlet & No RCD/RCBO Protection.	C2
6	L3	N	N	Hot Plate 2	Y	0.16	N/A	N/A	N/A			Broken Socket outlet & No RCD/RCBO Protection.	C3
7	L1	N	N	Heat Lamps 2	Y	0.09	N/A	N/A	N/A			No RCD/RCBO Protection.	C3
7	L2	N	N	Trayside Lights	Y	0.13	N/A	N/A	N/A			No RCD/RCBO Protection.	C3
7	L3	N	N	Plinth Lights	Y	0.14	N/A	N/A	N/A			No RCD/RCBO Protection.	C4

Entering test results and observations

The table below explains how the different results will impact the circuit test date, i.e. if the test date is not updated, the circuit will be deemed NOT tested, the test dates are updated based on the Zs value, if there is no Zs value the test date is not updated, a reason should be provided for the missing values.

With reference to the table above

1	L1	The circuit was not accessible and could not be tested No test results are entered, The Observations indicating the reason for not testing has been entered No Zs value implies the last/Next test date will NOT be updated and the circuit will be “untested”
2	L1	No tests carried out No test results No comment on the reason No Zs value implies the last/Next test date will NOT be updated and the circuit will be “untested”
3	L1	<i>Same as 2L1:</i> No tests carried out No test results No comment on the reason

		No Zs value implies the last/Next test date will NOT be updated and the circuit will be “untested”		
4	L1	Test carried out Some limitations, Note there is a value in the Zs field Limitation described Cat Code: FIO Zs value implies the last/Next test date WILL be updated and the circuit will be set as “tested”		
5	L1	Test carried out Some limitations, Note the LIM value in the Zs field Limitation described Cat Code: LIM Zs value implies the Last/Next test date WILL be updated and the circuit will be set as “tested”		
6	L1	Test carried out No Material Limitations Any comments and findings described in the Observations Zs value implies the Last/Next test date WILL be updated and the circuit will be set as “tested”		
7	L1	Test carried out No Material Limitations Any comments and findings described in the Observations Note that the Cat Code for 7 L3- is an undefined value, i.e. C4, this will be flagged as an ERR in the report. Zs value implies the Last/Next test date WILL be updated and the circuit will be set as “tested”		

COMPLETING THE CERTIFICATE AND UPDATING THE COMPLIANCE DETAILS

The CASE 3 for completion is applied. Note these can be overwritten at the time of certificate completion. In this case. The data in the certificate schedules will replace the data in the final board schedule; **if the Zs=0 or blank the last test next test date will not be updated because the assumption is that the the circuit has not been tested if there is no value. If there is a**

value, e.g. numeric or LIM, the system will assume that the circuit has been tested and update the last/next test dates.

☐ **CASE 1** - (Default) Test data retained; Changes to circuit details only if Zs>0 or Zs=lim; Last test/Next test date updated if Zs>0

If Zs in tested circuit >0 the data in the certificate schedules will replace the data in the final board schedule. Last test/Next test date for the circuit will only be updated if Zs>0; if the Zs=blank no changes will be applied in the final board schedule; if Zs=Lim the last test next test date will not be updated.

Use if you want the circuit details to be the same as the final circuit details except where Zs =0 or Zs=blank; e.g. if Zs is blank, and the circuit description is "Not Tested", the circuit description will not appear on the final schedule, that is, the final schedule will retain the original circuit description because Zs=blank.

☐ **CASE 2** - Test data retained; No change to circuit details; Only last test/Next test date updated if Zs>0 or Zs =lim

No changes in the tested circuit details will be applied to the final board schedule. Test data will be retained and if Zs>0 or Zs=lim the last test / next test date in the final schedule will be updated.

Use if you do not want to update any circuit details. (Note: the last test date will be updated if the Zs>0 or Zs=lim no other changes will be updated in the final schedule)

☒ **CASE 3** - Test data retained; Changes to circuits details regardless of Zs value; Last test/Next test date updated if Zs>0 or Zs=lim

The data in the certificate schedules will replace the data in the final board schedule; if the Zs=0 or blank the last test next test date will not be updated because the circuit has not been tested.

Use if you want all circuit details in the certificate to appear in the final schedule.

☐ **CASE 4** - Test data retained; Changes to circuit details regardless of Zs value; Last test/Next test date updated regardless of Zs value

All data in the certificate schedules will replace the all data in the final board schedule.

Use if you want the test schedule to be exactly the same as the final schedule and you want the last test/next test dates on the circuit to be updated for all circuits.

The RESULTING DATA UPDATES

Last/next test dates for the circuits

The resulting distribution board schedule and changes in the last/next test dates for the above example are shown below. Based on the CASE 3 scenario; any circuits that have no Zs value are not updated, and last/next test dates remain unchanged.

CR-01/1 DB														
Circuit Number and Phase	Circuit Designation	Type of wiring	Reference Method	Number of Points served	Circuit Conductors: csa		Max. disconnection time permitted by BS 7671(s)	Overcurrent Protection Device				RCD operating current, I _{pn} (mA)	Maximum Z ₀ permitted by BS 7671	Test Date - Next Test
					Live (mm ²)	cpc (mm ²)		BS (EN)	Type No	Rating (A)	Short-circuit capacity (kA)			
1 - L1	Socket on Panel 1 & Lowerator	B	B	2	4	4	0.4	60898	C	20	N/A	1	10	01/01/2019-01/01/2024
1 - L2	Socket on Panel 3	B	B	1	4	4	0.4	60898	C	20	N/A	1	10	01/01/2019-01/01/2024
1 - L3	Socket on Panel 4	B	B	1	4	4	0.4	60898	C	20	N/A	1	10	01/01/2019-01/01/2024
2 - L1	Induction Hob 1 Socket	B	B	1	2.5	2.5	0.4	60898	C	16	N/A	1.3	10	01/01/2019-01/01/2024
2 - L2	Induction Hob 2 Socket	B	B	1	2.5	2.5	0.4	60898	C	16	N/A	1.3	10	01/01/2019-01/01/2024
2 - L3	Cold Well	B	B	1	2.5	2.5	0.4	60898	C	16	N/A	1.3	10	01/01/2019-01/01/2024
3 - L1	Soup & Lowerator	B	B	2	2.5/4	2.5/4	0.4	60898	C	16	N/A	1.3	10	01/01/2019-01/01/2024
3 - L2	Hot Cupboard Near	B	B	1	2.5	2.5	0.4	60898	C	16	N/A	1.3	10	01/01/2019-01/01/2024
3 - L3	Hot Cupboard Far	B	B	1	2.5	2.5	0.4	60898	C	16	N/A	1.3	10	01/01/2019-01/01/2024
4 - L1	Hot Plate 6	B	B	1	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	29/01/2024-29/01/2029
4 - L2	Heat Lamps 6	B	B	1	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	29/01/2024-29/01/2029
4 - L3	Hot Plate 5	B	B	1	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	29/01/2024-29/01/2029
5 - L1	Heat Lamps 5	B	B	3	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	29/01/2024-29/01/2029
5 - L2	Hot Plate 4	B	B	1	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	29/01/2024-29/01/2029
5 - L3	Heat Lamps 4	B	B	3	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	29/01/2024-29/01/2029
6 - L1	Hot Plate 3	B	B	1	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	29/01/2024-29/01/2029
6 - L2	Heat Lamps 3	B	B	3	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	29/01/2024-29/01/2029
6 - L3	Hot Plate 2	B	B	1	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	29/01/2024-29/01/2029
7 - L1	Heat Lamps 2	B	B	3	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	29/01/2024-29/01/2029
7 - L2	Trayside Lights	B	B	1	1.5	1.5	0.4	60898	C	6	N/A	3.6	10	29/01/2024-29/01/2029
7 - L3	Plinth Lights	B	B	1	1.5	1.5	0.4	60898	C	6	N/A	3.6	10	29/01/2024-29/01/2029

Observations and recommendations

The Observations and recommendation for the certificate is shown in the Excel export of Observations and Recommendations below:

F	G	H	I	J	K
Item					Severity
Number	Board/Circuit	Estate Remedial Group	Observation Group	Item Text	Code
1	CR-01/1 DB, 1 L1		TEST LIMITATIONS	lim1- ACCESS RESTRICTED	FI
2	CR-01/1 DB, 1 L2		TEST LIMITATIONS	lim2 - NOT ABLE TO OPEN BOARD	FI
3	CR-01/1 DB, 1 L3		TEST LIMITATIONS	Lim3 - could not locate	FI
10	CR-01/1 DB, 4 L1		TEST LIMITATIONS	Zs by calculation	FIO
11	CR-01/1 DB, 4 L2		TEST LIMITATIONS	Zs by calculation	FIO
12	CR-01/1 DB, 4 L3		TEST LIMITATIONS	Zs by calculation	FIO
13	CR-01/1 DB, 5 L1		TEST LIMITATIONS	Zs not possible due to a	LIM
14	CR-01/1 DB, 5 L2		TEST LIMITATIONS	Zs not possible due to a	LIM
15	CR-01/1 DB, 5 L3		TEST LIMITATIONS	Zs not possible due to a	LIM
4	CR-01/1 DB, 6 L1			No RCD/RCBO Protection.	C3
5	CR-01/1 DB, 6 L2			Broken Socket outlet & No RCD/RCBO Protection.	C2
6	CR-01/1 DB, 6 L3			Broken Socket outlet & No RCD/RCBO Protection.	C3
7	CR-01/1 DB, 7 L1			No RCD/RCBO Protection.	C3
8	CR-01/1 DB, 7 L2			No RCD/RCBO Protection.	C3
9	CR-01/1 DB, 7 L3			No RCD/RCBO Protection.	C3

AFTER TESTING AND CERTIFICATE COMPLETION

The overall results are summarised as follows:

Circuit results

K. LIST OF BOARDS IN THIS CERTIFICATE - 115724					
Number of boards:	1	Total number of circuits:	21	Number of SPARE circuits:	0
Number of boards where Zdb is a numeric value:	0	Number of circuits with a Zs excluding SPARES	9	Number of circuits where Zs=LIM, excluding SPARE:	3
		Number of circuits where Zs=blank or 0, excluding SPARE:	9	Number of circuits with other value, excluding SPARES:	0
Board Designation	Phase	Ways	Board Type	Section	Floor
CR-01/1 DB	3	7			
The attached schedule(s) are part of this document and this report is valid only when they are attached to it.					

CIRCUITS DUE BEFORE TEST:

21 Circuits due for testing 01/01/2024

CIRCUITS DUE AFTER TEST:

9 x circuits due for testing 01/01/2024 (12 circuits tested, 29/01/2024 and due in 29/02/2030)

TEST LIMITATIONS:

3 x circuits -deemed not tested (Zs= blank), with a TEST LIMITATION explanation (no access)

3 x circuits – deemed not tested (Zs= blank), with no explanation (no data, no observation)

6 x-deemed tested (Zs has a value), with a limitation or a “For Info Only” (FIO) notice

6 x-deemed tested with no limitation (Zs has a value), but with an observation

The results are reported in EDIS, there are views for each stakeholder:

PDF Certificate

The example below shows the Schedule of Test results, values entered and notes for the circuits.

SCHEDULE OF TEST RESULTS FOR THE INSTALLATION : CR-01/1 DB																		
TO BE COMPLETED ONLY IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION										TEST INSTRUMENTS (SERIAL NUMBERS) USED								
Distribution board designation: CR-01/1 DB										Earth fault loop impedance		mft-001		RCD		n/a		
Zs at DB 0 Ω										Insulation resistance		n/a		Other		N/A		
Ipf at DB 0 kA										Continuity		n/a		Other		N/A		
Correct Supply: - Phase Sequence: - SPD Status: Operational N/A																		
Details of circuits and/or installed equipment vulnerable to damage when testing:															Next test date:		29/01/2029	
Circuit number and phase	Circuit impedances (Ω)					Insulation Resistance Test Voltage (V)	Insulation resistance Record lower or lowest value		Polarity # (V)	Zs Maximum Measured (Ω)	RCD		AFDD	Remarks				
	Ring final Continuity [measured end to end] (Ω)		Continuity [at least one column to be completed] (Ω)		Live/Line (MΩ)		Live/Earth (MΩ)	Disconnection Time at I _{Δn} (ms)			Test Button Operation (V)							
	r1 (Line)	r _n (Neutral)	r2 (cpc)	R1+R2								R2						
1 L1	-	-	-	-	-	-	-	-	-	-	-	-	-	TEST LIMITATIONS : lim1- ACCESS RESTRICTED - FI				
1 L2	-	-	-	-	-	-	-	-	-	-	-	-	-	TEST LIMITATIONS : lim2 - NOT ABLE TO OPEN BOARD - LIM				
1 L3	-	-	-	-	-	-	-	-	-	-	-	-	-	TEST LIMITATIONS : Lim3 - could not locate - FI				
2 L1	-	-	-	-	-	-	-	-	-	-	-	-	-					
2 L2	-	-	-	-	-	-	-	-	-	-	-	-	-					
2 L3	-	-	-	-	-	-	-	-	-	-	-	-	-					
3 L1	-	-	-	-	-	-	-	-	-	-	-	-	-					
3 L2	-	-	-	-	-	-	-	-	-	-	-	-	-					
3 L3	-	-	-	-	-	-	-	-	-	-	-	-	-					
4 L1	N/A	N/A	N/A	0.1	-	500	LIM	LIM	✓	0.11	N/A	N/A	N/A	TEST LIMITATIONS : Zs by calculation - FIO				
4 L2	N/A	N/A	N/A	0.08	-	500	LIM	LIM	✓	0.11	N/A	N/A	N/A	TEST LIMITATIONS : Zs by calculation - FIO				
4 L3	N/A	N/A	N/A	0.070	-	500	LIM	LIM	✓	0.16	N/A	N/A	N/A	TEST LIMITATIONS : Zs by calculation - FIO				

* Not all RCDs have a test button. Indication

J. OBSERVATIONS AND RECOMMENDATIONS FOR ACTIONS TO BE TAKEN														
Referring to the attached schedules of inspection and test results, and subject to the limitations at D:														
(The items in this section provide observations and recommendations for remedial actions.)														
Item No												Board/Circuit reference		Classification Code

DISTRIBUTION BOARD AND CIRCUIT OBSERVATIONS														
1	TEST LIMITATIONS : lim1- ACCESS RESTRICTED										CR-01/1 DB: 1 L1		FI	
2	TEST LIMITATIONS : lim2 - NOT ABLE TO OPEN BOARD										CR-01/1 DB: 1 L2		FI	
3	TEST LIMITATIONS : Lim3 - could not locate										CR-01/1 DB: 1 L3		FI	
4	No RCD/RCBO Protection.										CR-01/1 DB: 6 L1		C3	
5	Broken Socket outlet & No RCD/RCBO Protection.										CR-01/1 DB: 6 L2		C2	
6	Broken Socket outlet & No RCD/RCBO Protection.										CR-01/1 DB: 6 L3		C3	
7	No RCD/RCBO Protection.										CR-01/1 DB: 7 L1		C3	
8	No RCD/RCBO Protection.										CR-01/1 DB: 7 L2		C3	
9	No RCD/RCBO Protection.										CR-01/1 DB: 7 L3		C3	
10	TEST LIMITATIONS : Zs by calculation										CR-01/1 DB: 4 L1		FIO	
11	TEST LIMITATIONS : Zs by calculation										CR-01/1 DB: 4 L2		FIO	
12	TEST LIMITATIONS : Zs by calculation										CR-01/1 DB: 4 L3		FIO	
13	TEST LIMITATIONS : Zs not possible due to...										CR-01/1 DB: 5 L1		LIM	
14	TEST LIMITATIONS : Zs not possible due to...										CR-01/1 DB: 5 L2		LIM	
15	TEST LIMITATIONS : Zs not possible due to...										CR-01/1 DB: 5 L3		LIM	

Distribution board Schedule updated

The example shows the last/next test dates

CR-01/1 DB														
Circuit Number and Phase	Circuit Designation	Type of wiring	Reference Method	Number of Points served	Circuit Conductors: csa		Max. disconnection time permitted by BS 7671(s)	Overcurrent Protection Device				RCD operating current, I _{Dn} (mA)	Maximum Z _s permitted by BS 7671	Test Date - Next Test
					Live (mm ²)	cpc (mm ²)		BS (EN)	Type No	Rating (A)	Short-circuit capacity (kA)			
1 - L1	Socket on Panel 1 & Lowerator	B	B	2	4	4	0.4	60898	C	20	N/A	1	10	01/01/2019-01/01/2024
1 - L2	Socket on Panel 3	B	B	1	4	4	0.4	60898	C	20	N/A	1	10	01/01/2019-01/01/2024
1 - L3	Socket on Panel 4	B	B	1	4	4	0.4	60898	C	20	N/A	1	10	01/01/2019-01/01/2024
2 - L1	Induction Hob 1 Socket	B	B	1	2.5	2.5	0.4	60898	C	16	N/A	1.3	10	01/01/2019-01/01/2024
2 - L2	Induction Hob 2 Socket	B	B	1	2.5	2.5	0.4	60898	C	16	N/A	1.3	10	01/01/2019-01/01/2024
2 - L3	Cold Well	B	B	1	2.5	2.5	0.4	60898	C	16	N/A	1.3	10	01/01/2019-01/01/2024
3 - L1	Soup & Lowerator	B	B	2	2.5/4	2.5/4	0.4	60898	C	16	N/A	1.3	10	01/01/2019-01/01/2024
3 - L2	Hot Cupboard Near	B	B	1	2.5	2.5	0.4	60898	C	16	N/A	1.3	10	01/01/2019-01/01/2024
3 - L3	Hot Cupboard Far	B	B	1	2.5	2.5	0.4	60898	C	16	N/A	1.3	10	01/01/2019-01/01/2024
4 - L1	Hot Plate 6	B	B	1	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	29/01/2024-29/01/2029
4 - L2	Heat Lamps 6	B	B	1	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	29/01/2024-29/01/2029
4 - L3	Hot Plate 5	B	B	1	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	29/01/2024-29/01/2029
5 - L1	Heat Lamps 5	B	B	3	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	29/01/2024-29/01/2029
5 - L2	Hot Plate 4	B	B	1	2.5	2.5	0.4	60898	C	10	N/A	2.1	10	29/01/2024-29/01/2029

THE UPDATED COMPLIANCE REPORTS

BEFORE:

BEFORE:

INTERIM STATUS REPORT AS AT 30 DECEMBER 2023															
Estate:		Demo Estate													
Building Name	Test Coverage	C1	C2	C3	FI	LIM	NV	FIO	NCFI	ERR	Energised Ccts (Total non-spares)	Ccts Not Due for testing	Ccts Due for testing	Last 5 Inspection Dates	Latest Inspected Certificate
Belsize	0%	0	0	0	0	0	0	0	0	0	21	0	21	30/01/2019	11500

AFTER:

INTERIM STATUS REPORT AS AT 30 JANUARY 2024															
Estate:		Demo Estate													
Building Name	Test Coverage	C1	C2	C3	FI	LIM	NV	FIO	NCFI	ERR	Energised Ccts (Total non-spares)	Ccts Not Due for testing	Ccts Due for testing	Last 5 Inspection Dates	Latest Inspected Certificate
Belsize	57%	0	1	5	3	3	0	3	0	0	21	12	9	30/01/2019	11500

This summarises:

- The test coverage i.e. 12 circuits tested out of 21.
- The number of Observations, specifically 3 x FI's, that have not had access.

CONCLUSION AND RECOMMENDATIONS

This document is not a replacement for good electrical engineering judgment or electrical wiring standards; It's only aims to illustrate how the EDIS system can assist in providing better process and information for improving electrical compliance in a building.

Following the data recording described in this document will lead to better electrical compliance reporting.